

**South Alabama  
Purchasing Association**

**ADDENDUM - 5**

**REFERENCE: SAPA RFB 2020-07**

**BID: “Water & Sewer Inventory of SAPA Utility Members”**

**Wayne Smith,  
SAPA Coordinator**

***Please Note:***  
***This Addendum must be returned along with the bid documents.***

## ADDENDUM – 5

Date Issued: October 7, 2020

### CHANGES IN BID

Please note: Page 14 & 15 of section 6.7, Category “C” Specification for Ductile Iron Mechanical Joint Fittings for WATER it calls out a Sewer Pipe coating of ceramic Epoxy lining which is not NSF 61 approved and not recommended that for water service as well as most of the manufactures listed.

**-Please change to-**

**The interior of all pipe shall be cement-mortar lined as specified in AWWA Specification C104 and the exterior shall receive an approved bituminous coating. All gaskets, bolts and lubricants shall be furnished.**



Wayne Smith, SAPA Coordinator

*Associated with:*

*South Alabama Regional  
Planning Commission*



Email: [waynesmith@sarpc.org](mailto:waynesmith@sarpc.org)

Website: [www.sarpc.org](http://www.sarpc.org)